

CRUHSD

Fieldhouse

Bullhead City, Arizona



REQUEST for PROPOSAL (RFP) Artificial Turf - COVER

Addendum # 2

ISSUED June 16, 2018

OWNER: Colorado River Union High School District

PROJECT MANAGER: International Coliseums Company (ICC)
Contact: Robert Tamborski (480) 993-0297

CONSTRUCTION MANAGER: CORE Construction

ARCHITECT: Orcutt Winslow & Sink Combs Dethlefs

DUE DATE OF BID PROPOSAL: June 24, 2018

Addendum # 2

To: All Plan holders of Record

This addendum modifies the RFP documents as noted below.

CORRECTION: Bid documents are not available in local newspaper.

NOTICE: The RFP due date has been extended till August 24, 2018, and all RFP documents, including Addendum #1 & #2 are posted on the CRUHSD website. All documents, drawings, specifications and addendums are available on the site listed below:

https://www.crsk12.org/departments/business_department/purchasing

Please acknowledge receipt of this addendum in your proposal.

Questions: (answers in *BOLD Bullet*)

1. You have the medium duty – drivable listed as “open bottom”. The “closed back / flat back” is the drivable as it gives you full contact with the surface, allowing for even distribution of load. The pedestrian grade is the “open bottom” version. As the RFP stands presently, I would be submitting open bottom for both sections. Please confirm if this is your intention.
 - ***Artificial Turf manufacturers are recommending an open bottom tile as their experience as shown there is less damage to the turf when covers are on for an extended time.***
 - ***Please provide technical data of load capability and what types of vehicles would or would work well with your cover type.***
 - ***Bidders can submit additional bids for closed bottom floor, along with references for project installations and owners contact information.***
 - ***Please explain the loading capable for each type of flooring and what type of vehicles can drive on it.***
 -

Answers to bidder's inquiries will be made available to all bidders and posted on the CRUHSD website.